

Ord. No. 596 UNIFORM FIRE CODE Adopted: April 9, 2018

An ordinance to adopt by reference the NATIONAL FIRE PROTECTION ASSOCIATION ("NFPA 1") UNIFORM FIRE CODE, 2018 EDITION, and ANNEXES and INDEX; to prescribe regulations for the safeguarding to a reasonable degree of life and property from the hazards of fire and explosion; to amend certain provisions of the said NFPA 1/UNIFORM FIRE CODE 2018 including conflicts between it and the state construction code; open fires; premises markings; board of appeals; records; existing apartments buildings; indication of central service station; and means of egress inspections; and to repeal existing Ordinances or parts of Ordinances in conflict herewith.

THE CHARTER TOWNSHIP OF KALAMAZOO, KALAMAZOO COUNTY, MICHIGAN, ORDAINS:

596.001 - TITLE

This Ordinance shall be known and cited as the "Kalamazoo Charter Township UNIFORM FIRE CODE Ordinance".

596.002 - PURPOSE

This Ordinance is adopted pursuant to the authority vested in Townships by Section 1 of 1945 PA 246, as amended (MCLA 41.181), and Section 5 of 1951 PA 33, as amended (MCLA 41.805), the purpose of which Ordinance is to adopt a Uniform Fire Code with annexes, index, and amendments thereto; to prescribe regulations for the safeguarding to a reasonable degree of life and property from the hazards of fire and explosion arising from the storage, handling and use of hazardous substances, materials and devices, and from conditions hazardous to life or property in the use or occupancy of buildings or premises.

596.003 - ADOPTION OF "NFPA 1/UNIFORM FIRE CODE, 2018 EDITION"

A certain document or booklet, which is marked and entitled as "NFPA 1/UNIFORM FIRE CODE, 2018 EDITION" and the annexes and index thereto, said Code being published by the National Fire Protection Association, official copies of which are on file in the office of the Township Clerk and which may be examined by the general public during regular business hours or by appointment, is hereby adopted by reference as if fully set forth herein. Each and all of the regulations, provisions, penalties, conditions and terms thereof, except as they may hereafter be modified, shall be deemed adopted and made a part hereof by this reference as if fully set forth in this Ordinance.

596.004 - CONFLICTS

Section 1.3.3 of the said NFPA1/ UNIFORM FIRE CODE, 2018 EDITION, regarding "Conflicts" is hereby amended to add Section 1.3.3.3 as follows:

"1.3.3.3. Where a conflict between this document and the Michigan Construction Code occurs, the specific requirements of the Michigan Construction Code shall apply".

596.005 - BOARD OF APPEALS

Section 1.10.1.1 of the said NFPA1/ UNIFORM FIRE CODE, 2018 EDITION, is hereby amended to read as follows:

"1.10.1.1. A Board of Appeals shall be established consisting of members and alternate members who shall be appointed by the Charter Township of Kalamazoo Board of Trustees and whom by reason of education, experience, and knowledge and are deemed to be competent to sit in judgment on matters concerning this Code and its enforcement."

596.006 - OPEN FIRES

Section 10.10 of the said NFPA1/ UNIFORM FIRE CODE, 2018 EDITION, is hereby amended by the deletion of subsections 10.10.1 through 10.10.9 thereunder and by the addition of the following language:

"10.10 Open fires, incinerators and commercial fireplaces shall be regulated by separate Township Ordinance."

596.007 - PREMISES MARKINGS

Section 10.11.1.2 of the said NFPA 1/UNIFORM FIRE CODE, 2018 EDITION, is hereby amended to read as follows:

"10.11.1.2 Address number (other than 1 or 2 family dwellings) shall be a minimum of 10 inches (254 mm) high with a minimum stroke width of 2 inches (50.8 mm.)"

596.008 - RECORDS

Section 13.3.3.4.3.1.1 of the said NFPA 1/UNIFORM FIRE CODE, 2018 EDITION, is hereby amended to read as follows:

"13.3.3.4.3.1.1 Records of all system inspections, tests and maintenance required by the referenced standards shall be maintained on the premises for a minimum of three years and shall be copied to the Fire Marshal using a system as specified by the Fire Marshal."

596.009 - EXISTING APARTMENT BUILDINGS

Section 13.7.2.18.1 of the said NFPA 1/ Uniform Fire Code, 2018 EDITION, is hereby amended to read as follows:

"13.7.2.18.1 Apartment buildings with more than two stories or with more than 11 dwellings units, other than those meeting 13.7.2.8.1.2 of NFPA 101, shall be provided with a fire alarm system in accordance with Section 13.7 and NFPA 101, except as modified by 31.3.4.5.4 of NFPA 101. (101:31.3.4.1.1)""

596.010 - INDICATION OF CENTRAL STATION SERVICE

Section 13.7.3.4 of the said NFPA 1/UNIFORM FIRE CODE, 2018 EDITION is hereby amended to read as follows:

"13.7.3.4 Fire alarm systems required by this chapter or by the International Building Code shall be monitored by a listed central station as defined in NFPA 72. A Certificate or Placard shall be issued by a recognized listing organization that has listed the prime contractor for all newly installed fire alarm systems in commercial occupancies in accordance with NFPA 72. This regulation shall apply to all fire alarm systems that are newly installed in commercial occupancies for which permits are required. Any existing fire alarm system in a commercial occupancy wherein the fire alarm control panel and/or alarm system components are to be replaced shall be considered newly installed for the purposes of this section. Also, where there is reasonable cause due to non-compliance or faulty conditions, the fire marshal may require an existing fire alarm system meet the same requirement as a newly installed system. Central station service in full compliance with the 2016 Edition of NFPA 72, shall be maintained at the protected property, so long as the requirement for the fire alarm system exists."

596.011 - FIRE DEPARTMENT ACCESS ROADS

Section 18.2.3.5.1.1 of the said NFPA 1/UNIFORM FIRE CODE, 2018 EDITION, is hereby amended to read as follows:

"18.2.3.5.1.1 Fire department access road shall have an unobstructed width of not less than 25 ft. (7.62 m)."

596.012 - MARKING OF FIRE DEPARTMENT ACCESS ROADS

Section 18.2.3.6.1 of the said NFPA 1/UNIFORM FIRE CODE, 2018 EDITION, is hereby amended to read as follows:

“18.2.3.6.1 Where required by the AHJ, Approved Signs, with the language of “FIRE LANE NO PARKING, STOPPING OR STANDING” shall be provided and maintained to identify fire department access roads or to prohibit the obstruction thereof or both.”

596.013 - MEANS OF EGRESS INSPECTION

Section 20.1.5.1.1 of the said NFPA 1/ UNIFORM FIRE CODE, 2018 EDITION, is hereby amended to read as follows:

“20.1.5.1.1 Means of Egress Inspection. The building owner or agent of all public assembly occupancies shall inspect the means of egress to ensure it is maintained free of obstructions, and correct any deficiencies found, prior to each opening of the building to the public and prepare and maintain records of the date and time of each inspection on approved forms, listing any deficiencies found and any action taken to correct them.”

596.014 – FIRE PROTECTION SYSTEMS

A new section designated 13.1.13 is hereby added to the NFPA 1/UNIFORM FIRE CODE, 2018 EDITION to read, in its entirety, as follows:

13.1.13 Signage on Fire Department Connections. Fire Department Connections (FC) shall be signed/marked so as to be easily identified at the time of an emergency. Signage shall be white on red reflective signage and letters shall be at least 6 inches in height and approved by the AHJ. (Ord. No. 610, Sec. 12, 8/26/2019)

596.015 – WATER SUPPLIES AND FIRE HYDRANTS

A new section designated 18.3.4.2 is hereby added to NPFA 1/Uniform Fire Code, 2018 Edition, to read, in its entirety, as follows:

18.3.4.2 Fire Hydrant and Stand Pipe Signage. All fire hydrants shall be identified by signage as utilized by the local water provider or approved by the AHJ. Stand Pipes shall be identified as such by signage approved by the AHJ. (Ord. No. 610, Sec. 12, 8/26/2019)

596.016 - VIOLATIONS

Any person, firm, association, partnership, corporation, or governmental entity who violates any of the provisions of this Ordinance or fails to comply with a duly authorized Order issued pursuant to this Ordinance shall be deemed to be responsible for a municipal civil infraction as defined by Michigan Statute which shall be punishable in accordance with the following schedule:

	Minimum Fine	Maximum Fine
1st offense within 3-year period*	\$150.00	\$500.00
2nd offense within 3-year period*	\$250.00	\$500.00
3rd offense within 3-year period*	\$350.00	\$500.00
4th or more offense within 3-year period*	\$500.00	\$500.00

*Determined on the date of commission of the offense(s).

Additionally, the violator shall pay costs which may include all expenses, direct and indirect, the Charter Township of Kalamazoo has incurred in connection with the municipal civil infraction. In no case, however, shall costs of less than \$10.00 nor more than \$500.00 be ordered. In addition, the Township shall have the right to proceed in any court of competent jurisdiction for the purpose of obtaining an injunction, restraining order, or other appropriate remedy to compel compliance with this Ordinance. Each day that a violation of this Ordinance exists shall constitute a separate violation.

596.017 - SAVINGS CLAUSE

Any prosecution or other court case pending on the effective date of this Ordinance on a part of portion of an ordinance that is repealed herein shall be permitted to continue to its natural conclusion as if the provision was not repealed.

596.018 - EFFECTIVE DATE, SEVERABILITY AND REPEAL OF CONFLICTING ORDINANCES

The within ordinance shall take effect 30 days after publication of a summary hereof, after adoption by the Township Board. The provisions of this Ordinance are hereby declared to be severable. If any clause, sentence, paragraph, section or subsection is declared void or inoperable for any reason, it shall not affect any other part or portion thereof. All Ordinances or parts of Ordinances in conflict herewith are hereby repealed.